

## GENERAL NOTES:

- 1. INSTALLATION SHALL GENERALLY BE FOR A MAIN-LINE 12" AND SMALLER. INSTALLATION OF OTHER SIZED VALVES IS SIMILAR.
- VALVE VAULT SHALL BE TYPE "E", SEE DETAIL 295-1. FOR PRESSURE REDUCING VALVES LARGER THAN 6", VAULT SIZE SHALL BE INCREASED TO ACCOMMODATE LARGER APPURTENANCES. LARGER VAULT DIMENSIONS MUST BE APPROVED BY THE EPWU.
- 3. PRESSURE RELIEF VALVE MAY BE LOCATED EITHER UPSTREAM OR DOWNSTREAM OF PRESSURE REDUCING VALVE DEPENDING ON A SUITABLE DISCHARGE LOCATION. WHEN RELIEF VALVE IS LOCATED DOWNSTREAM REDUCING VALVE SHALL BE EQUIPPED WITH A PRESSURE RELIEF PILOT AS NOTED IN A AND N. RELIEF VALVE SIZE IS GENERALLY ONE OR TWO SIZES SMALLER THAN THE SIZE OF THE MAINLINE. SEE EPWU STANDARD DETAILS 265-1 THROUGH 265-8 FOR INSTALLATION.
- 4. 12"x24" FOOTING WITH No.5 REBAR AT 12" ON CENTER EACH WAY IS REQUIRED.
- 5. TEST OUTLETS TO BE PLACED BEFORE AND AFTER PRESSURE REDUCERS. SEE DETAIL 264-5 FOR TEST OUTLET DETAIL.

## **CONSTRUCTION KEY NOTES:**

- A. 6" FLANGED PRESSURE REDUCING VALVE, WITH SURGE RELIEF PILOT, FOR HIGH FLOWS.
- B. 6" FLANGED DUCTILE IRON SPOOL.
- D. 6"x¾" TAPPING SADDLE & ¾" TEST OUTLET WITH CORPORATION STOP.
- E. 6" FLANGED 90° BEND.
- F. 6" FLANGED GATE VALVE WITH HANDWHEEL.
- G. 6"x2" FLANGED TEE.
- J. 6" FLANGED GATE VALVE WITH VALVE BONNET BOX AND COVER.
- K. GATE VALVE (CLOSED) SIZE AS SPECIFIED, WITH VALVE BONNET BOX AND COVER.
- L. MAINLINE, SIZE AS SPECIFIED.
- M. MECHANICAL JOINT TEE WITH A 6" FLANGED BRANCH, MAINLINE SIZE AS SPECIFIED.
- N. 2" FLANGED PRESSURE REDUCING VALVE, WITH SURGE RELIEF PILOT, FOR LOW FLOWS.
- O. 2" FLANGED BRASS OR DUCTILE IRON SPOOL.
- P. 2" FLANGED GATE VALVE WITH HANDWHEEL.
- Q. VALVES INSTALLED ON NATURAL GROUND WITH CONCRETE SUPPORTS AS REQUIRED.
- R. WALL SLEEVES AND/OR GROUT.
- S. 2"x1" BRONZE TEE WITH 1" TO ¾" ADAPTER & ¾" TEST OUTLET WITH CORPORATION STOP.

STANDARD DETAIL

DATE: 7/1994 REV: 7/20/2009 PRESSURE REDUCING 6" VALVE (BY-PASSED)
BEHIND CURB INSTALLATION

