

**EL PASO WATER
PURCHASING DEPARTMENT
1154 HAWKINS BLVD.
EL PASO, TEXAS 79925**

GRANULAR ACTIVATED CARBON

BID NUMBER 29-20

ADDENDUM NUMBER 1

MAY 1, 2020

Attention of all bidders is directed to the following addendum to this Bid Proposal:

A. Delete (remove and discard) page 30; replace with the attached *revised* page 30-R¹.

B. Response(s) to Bidder's question(s):

- Question: The carbon specification calls for Filtrasorb 816 re-agglomerated carbon or an approved equal. Can you please confirm that the carbon supplied must be domestic like Filtrasorb 816.

Answer: The spec reads "the product...shall be compatible to Calgon Carbon Filtrasorb 816...or approved equal". This implies that the GAC shall be supplied domestic like Filtrasorb 816.

- Question: Do you have a copy of the current contract / winning Proposal from last time this RFP was released? Or, at minimum, the contracted price for this contract?

Answer: For a current contract/winning proposal, you'll need to put in an Open Records Request. The current contracted price is \$1.47/lb.

Bidder shall acknowledge receipt of this addendum and submit this acknowledgment with their bid submittal. Failure to acknowledge addendum(s), may result in rejection of bid.



Gretchen Garcia
Procurement Analyst

BIDDER'S ACKNOWLEDGEMENT OF RECEIPT


RGuevara

This product for the Jonathan Rogers Water Treatment Plant, Upper Valley Water Treatment Plant, Robertson-Umbenhauer Water Treatment Plant, and Fred Hervey Water Reclamation Plant shall be compatible to Calgon Carbon FILTRASORB 816 Re-agglomerated carbon or **APPROVED EQUAL**. **Custom reactivated granular activated carbon is not acceptable. NO EXCEPTION OR SUBSTITUTE ALLOWED. The GAC supplied must be domestic.**